

Hanover High School

General Contractor:

Callahan Construction

- Superior Foundations Inc: Cited by The AGO for failing to pay prevailing wages, Restitution \$3,802.94 and Civil Penalty \$2,000.00. The AGO also cited them for failure to submit true and accurate payroll records. Civil Penalty \$2,000.00.
- Action Floors: Cited by the AGO for failure to submit true and accurate certified payroll, Civil Penalty \$2,000.00.
- VPS Drywall: Cited by OSHA with four violations totaling \$3,850.00
- Specialty Flooring Inc: Cited by OSHA for repeat violation totaling \$10,500.00
- Bristol Builders & Contractors Inc: \$3,500.00
- Newton Sheet Metal Inc: \$8,580.00
- Callahan Inc: Citation \$4,200.00

*Quality Control Issues:

- Concrete being out of level by 1.5 inches in 8ft. in several cases.
- Flooring Contractor doing the Gymnasium had to pull out until someone Grinds down the Concrete and resurfaces the entire floor.
- Entry doors to the class rooms had to be removed and then reinstalled because they were never fastened to the floor.
- The siding company had major problems wrapping the windows because they were out of square and out of plumb.
- The exterior soffit that encompasses 90% of the building had to be taken apart and reinstalled because VPS used the wrong fasteners.
- The parapet walls located on the roof had to be raised because they were built too low.
- The Carpenters had a tough time installing the exterior panels especially at the corners because the exterior walls were out of plumb.